

RURAL WATER DISTRICT NO. 2 WASHINGTON COUNTY, OK

P.O. Box 420 Ochelata, OK 74051 Phone: 918-535-2302 800-448-3264 FAX: 918-535-2981

Meter Size, Location, & Fire Suppression May 2021

1. Service from the water district is intended primarily for domestic use.
2. All residential service including yard sprinkler systems is to be provided through 5/8" x 3/4" "house" meters in appropriate meter settings.
3. Commercial service is to be negotiated on a case by case basis taking into consideration system capacity, property requirements and zoning.
4. Residential fire service (in home fire sprinkler systems) requires flows above the capacity of house meters. Upon special request the District will provide higher flows for residential fire service through a larger appropriately sized meter. This larger meter will have the following restrictions/requirements.
 - a. Restricted to serve fire sprinkler system only.
 - b. Home must be served with house meter for regular water needs.
 - c. Fire sprinkler meter will not be additional Benefit Unit or Membership on District.
 - d. Monthly minimum will be charged for fire service meter the same as house meter. No water will be allowed through fire service meter unless there is a fire.
 - e. District member requesting fire service meter will be charged District's cost to set meter. This meter setting cost is in addition to Membership Fee and any main extension cost.